



FIRE DEPARTMENT

8812 Elk Grove Blvd.
Elk Grove, CA 95624

(916) 405-7100
Fax (916) 685-6622
www.egcsd.ca.gov

PLAN SUBMITTAL REQUIREMENTS - CIVIL

I Purpose

To advise architects, engineers and contractors what minimum information is required for plan approval. All information listed below shall be on the plans.

II Scope

The following requirements shall apply to civil plans for all new buildings, tenant improvements, and building addition plans submitted to Elk Grove CSD Fire Department. Not all requirements listed apply to every submittal. If questions arise, contact the area inspector to determine what information may not be required.

III References

CBC and CFC are in reference to the 2001 California Building Code and 2001 California Fire Code.

Ordinance No. 37-2002 is a City of Elk Grove adopted ordinance amending the 2001 California Fire Code.

IV General

- A. Plans will not be accepted for review until the plan review fee is paid in full. Fees include the initial review and resubmittals.
- B. The District's plan review turn around time is approximately 15 business days.
- C. Plans may be "expedited" for an additional fee of \$107/hr (based upon fee rate in effect 7/1/04).
- D. Mylars/vellums shall be stamped and wet-signed by a licensed civil engineer prior to signature.
- E. Digital submittals shall accompany all hard copy plan check submittals when final plan has been approved and is ready for signature. The digital drawings shall contain the **ENTIRE project** and **ALL** external referenced ("XREF") digital drawing support files of the project. Submittal of digital drawings that fail to include all support data will not be accepted. Fire Department final inspection will not commence until compliance with the digital submittal. All electronic formats shall be submitted on Windows OS formatted diskettes or on compact disk (CD). Emailed copies will **not** be accepted at this time. The submitted digital copy **shall be labeled with the project name and address of the project.**



FIRE DEPARTMENT

8812 Elk Grove Blvd.
Elk Grove, CA 95624

(916) 405-7100
Fax (916) 685-6622
www.egcsd.ca.gov

The entire project as it appears in the approved printed plans shall be submitted and comply with the following required data format.

DWG (applies to **AUTOCAD** drawing file format)-**Any AutoCAD DWG version is acceptable.**

Addresses for all subdivision lots shall be provided to the Fire Department within sixty (60) days of Fire Department signature of approval for such development plans. Inquiries about these requirements may be directed to Nick Gorman, GIS Coordinator at 916.405.7116.

- F. A minimum of two complete sets of plans shall be submitted each time plans are submitted or resubmitted.
- G. Approved architectural plans will not be released until civil plans are approved. Foundation permits may be issued upon approval of civil plans.
- H. UGS fees (underground fire service mains) shall be paid at the time civil plans are submitted. Manufacturer's specification sheets for all pipe, fittings, valves and appurtenances shall be provided by the installing contractor prior to inspection.

NOTE: If a different contractor is installing only the riser stub-in and the underground pipe 5 feet from the foundation, then that contractor installing the stub-in shall pay a ULI fee and submit manufacturer's specification sheets.

- I. Attached *Standard Civil Engineering Comments*, shall be copied onto plans in their entirety.
- J. All gates across fire access lanes require a separate submittal.
- K. Any deviations from the approved plans will require revised plans to be submitted.

V Title Sheet shall include the following information:

- a. Address of project location
- b. Name, address, phone number of engineer of record
- c. Location map showing the location of the project site in relation to major streets
- d. Sheet index
- e. Building analysis with the following info:
 - 1. Occupancy of building. If building houses more than one occupancy type, list each type.
 - 2. Construction type



FIRE DEPARTMENT

8812 Elk Grove Blvd.
Elk Grove, CA 95624

(916) 405-7100
Fax (916) 685-6622
www.egcsd.ca.gov

3. Square feet
4. Indicate whether or not the building has fire sprinklers.
4. List of applicable codes and the edition (2001 California Fire and Building Codes, NFPA 24)

VI Utilities Sheets shall include the following:

Not all requirements listed apply to every submittal. If questions arise, contact the area inspector to determine what information may not be required.

- A. Show location of fire access lanes by shading or cross hatching the entire length and width of the lane.

NOTE: Buildings exceeding 10,000 sq. ft. shall be provided with 2 points of fire department access a minimum of 500 feet apart.

- B. All turns in fire lanes shall have the radii labeled on the plans and to scale. Minimum turning radii are 50 feet outside and 25 feet inside.
- C. Note indicating that fire lanes shall be a minimum of 20 feet clear width and 13 ½ feet clear height. (unless parking on one or both sides mandates a wider lane – in that case the wider width shall be specified on the plans) CFC 902.2.2.1
- D. Indicate how fire lanes will be delineated – posting of signs or painted curbs.
- E. Location of all new and existing fire hydrants.
- F. Location and diameter of all underground mains.

NOTE:

1. Buildings exceeding 10,000 square feet and residential subdivisions exceeding 26 homes shall be provided with a minimum 10 inch looped fire service main (two points of water supply connection).
 2. Three or more hydrants supplied by a single main shall be looped (two points of water supply connection).
 3. Underground mains serving fire hydrants and exceeding 150 feet in length shall be minimum 8 inch.
- G. Location of the point of connection of new and existing underground mains.

NOTE: If the scope of work is to connect to new pipe that is part of the scope of a different project or a different phase of the same project, clearly state so on plans. All



FIRE DEPARTMENT

8812 Elk Grove Blvd.
Elk Grove, CA 95624

(916) 405-7100
Fax (916) 685-6622
www.egcsd.ca.gov

fire flow and hydrant requirements dependent upon another project or phase must be complied with prior to combustible materials being brought on site.

- H. Diameter of the public main(s) supplying the new main.
- I. Location of all control valves, post indicator valves, fire department connections, backflow preventers, and reduced pressure devices.

NOTE: Fire department connections shall be a minimum of 40 feet away from buildings and within 40 feet of a fire hydrant.

For projects with multiple buildings, hydrants, and/or multiple risers per building, sectional control valves shall be located to minimize interruption of water supply to the other hydrants and sprinkler risers.

- J. The following Sacramento County Public Works installation details shall be provided on plans as applicable: 8-2A, 8-2B, 8-3A, 8-4A, & 8-7.
- K. Indicate on plans the required fire flow. Some projects may require that a flow test be conducted. For projects within the Elk Grove Water Works Zone, contact Elk Grove Water Works at 9257 Elk Grove Blvd or (916)685-5376.
- L. Per the City of Elk Grove amendments/Sacramento County amendments to the 2001 California Fire Code (CFC), buildings that are provided with approved fire sprinklers may receive a 50% reduction in the required fire flow. See Table A-III-A-I of the 2001 CFC for specifications.

VII Resubmittals

- A. All changes shall be clouded and indicated with a delta that has a corresponding revision number and date.
- B. Plan review comments shall be addressed in a separate letter specifically addressing plan review comments.
- C. Indicate how the plan review comment was addressed and on what sheet the change or correction was made.
- D. All plan review comments must be addressed in order for plans to be approved. If there are any questions regarding code interpretation or the applicability of the code section cited, contact the area inspector to discuss the issue prior to resubmittal.